



TAKOMA REC LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	TAKOMA RECREATION CENTER	5/28/2016	WS- 005396	Utility	Basement	In pool room (water source)	WT-042916-5413- A	29	WT-042916-5413- B	5.6	Non-drinking water source - Not accessible to children			
2	TAKOMA RECREATION CENTER	5/28/2016	WS- 005397	Fountain	Basement	In women's locker room Right Low	WT-042916-5414- A	< 1	WT-042916-5414- B	< 1				
3	TAKOMA RECREATION CENTER	5/28/2016	WS- 005398	Fountain	Basement	In women's locker room Left High	WT-042916-5415- A	< 1	WT-042916-5415- B	< 1				
4	TAKOMA RECREATION CENTER	5/28/2016	WS- 005399	Fountain	Basement	In mens locker room Left High	WT-042916-5416- A	< 1	WT-042916-5416- B	< 1				
5	TAKOMA RECREATION CENTER	5/28/2016	WS- 005400	Fountain	Basement	In mens locker room Right Low	WT-042916-5417- A	< 1	WT-042916-5417- B	< 1				
6	TAKOMA RECREATION CENTER	5/28/2016	WS- 005401	Cooler	1	Adjacent to the Kitchen Right Low	WT-042916-5418- A	< 1	WT-042916-5418- B	< 1				
7	TAKOMA RECREATION CENTER	5/28/2016	WS- 005402	Cooler	1	Adjacent to the kitchen Left High	WT-042916-5419- A	< 1	WT-042916-5419- B	< 1				
8	TAKOMA RECREATION CENTER	5/28/2016	WS- 005403	Kitchen	1	In kitchen	WT-042916-5420- A	< 1	WT-042916-5420- B	< 1				
10	TAKOMA RECREATION CENTER	5/28/2016	WS- 005405	Kitchen	Ground Floor	In kitchen room 157	WT-042916-5422- A	< 1	WT-042916-5422- B	< 1				
15	TAKOMA RECREATION CENTER	5/28/2016	WS- 005410	Fountain	Ground Floor	Exterior adjacent to basketball court Right High	WT-042916-5427- A	< 1	WT-042916-5427- B	< 1				
16	TAKOMA RECREATION CENTER	5/28/2016	WS- 005411	Fountain	Ground Floor	Exterior adjacent to basketball court Left Low	WT-042916-5428- A	< 1	WT-042916-5428- B	1.1				
17	TAKOMA RECREATION CENTER	5/28/2016	WS- 005412	Kitchen	Ground Floor	Accessoru building in kitchen	WT-042916-5429- A	4	WT-042916-5429- B	< 1				
18	TAKOMA RECREATION CENTER	5/28/2016	WS- 005413	Cooler	Ground Floor	Accessory building in hall Left High	WT-042916-5430- A	< 1	WT-042916-5430- B	< 1				
19	TAKOMA RECREATION CENTER	5/28/2016	WS- 005414	Cooler	Ground Floor	Accessory building in hall Right Low	WT-042916-5431- A	< 1	WT-042916-5431- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.